



# Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
<b>afp - 3402</b>	30-Aug-2019	Number 2	Issue date 29-Apr-2021	30-Apr-2022

Page 1 of 3

## Product designation

**Cavius, Prod. Code 2008 CAV10, Single Pack (1 x Part Code 2008-001), 10 year lithium battery powered, silencing/hush feature, recess mount, photoelectric smoke alarm**

(Refer to the Schedule/enclosures for further specified details)

## Agent/distributor

Cavius Australia Pty Ltd  
Unit 14, 30 Octal St, YATALA, QLD, AUSTRALIA, 4207

## Registrant

Cavius Aps  
Julsøvej 16, SILKEBORG, DENMARK, 8600

### Producer

Cavius Aps  
Julsøvej 16, SILKEBORG, DENMARK, 8600

## Conformance criteria and evaluation

The Cavius, Prod. Code 2008 CAV10, Single Pack (1 x Part Code 2008-001), 10 year lithium battery powered, silencing/hush feature, recess mount, photoelectric smoke alarm has been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. Australian Standard AS 3786:2014, 'Smoke alarms using scattered light, transmitted light or ionization' incl. Amdt 1 (27 August 2015) / Amdt 2 (30 October 2018).
2. CSIRO Technical Specification TS-007, Version 3: 15-Sep-2016, 'Evaluation for Conformity of smoke alarms to the requirements of AS 3786:2014'.

## Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Issued by

David Whittaker  
Executive Officer – ActivFire Scheme



# Schedule to Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
<b>afp - 3402</b>	30-Aug-2019	Number 2	Issue date 29-Apr-2021	30-Apr-2022

## Producer's description

The Cavius, Prod. Code 2008 CAV10, Single Pack (1 x Part Code 2008-001), 10 year lithium battery powered, silencing/hush feature, recess mount, photoelectric smoke alarm with Recess Kit is a low profile, circular styled, 3 V self-contained smoke alarm intended for use in residential dwellings.

An electric buzzer/horn provides an audible alarm signal when the smoke alarm senses smoke which exceeds a pre-determined level. When the smoke level drops below the alarm level, the buzzer/horn is de-energized. A self-test facility is provided. If the button is depressed an alarm signal is emitted. The battery is not user-replaceable.

This equipment senses smoke using the photoelectric principle. An electric buzzer/horn provides an audible alarm signal when the smoke alarm senses smoke which exceeds a pre-determined level. When the smoke level drops below the alarm level, the buzzer/horn is de-energized.

A self-test facility is provided by means of a button. If the button is depressed an alarm signal is emitted.

A 'silence button' feature is also incorporated with the 'test' button. Pressing the 'silence button' can temporarily quiet an unwanted alarm for up to 10 minutes.

Pressing the silence button can temporarily quiet an unwanted alarm for up to 10 minutes.

The Cavius, Prod. Code 2008 CAV10, Single Pack (1 x Part Code 2008-001), 10 year lithium battery powered, silencing/hush feature, recess mount, photoelectric smoke alarm is circular in shape. It is approximately 30 mm diameter with a height of 43 mm.

## Technical specification

The following details are a representative extract of the technical specification for the Cavius, Prod. Code 2008 CAV10, Single Pack (1 x Part Code 2008-001), 10 year lithium battery powered, silencing/hush feature, recess mount, photoelectric smoke alarm and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

### Schedule of variant designations

The following is a schedule of validated variant designations of the certified/listed equipment.

Variant		Description	Recess mount
Type	Ident.		
Product code	2008 CAV10	Single pack, 1 x Cavius, Part Code 2008-001 smoke alarm	Part Code 11010
Part code	2008-003		

### Schedule of properties/characteristics

The following schedule is an extract of physical and operational properties/characteristics of the certified/listed equipment.

<b>Sensor:</b>	Photoelectric (Type A)	
<b>Electrical:</b>	3 Vdc (CR123A Lithium battery, non-replaceable)	
<b>Alarm volume:</b>	85 dB(A) at 3 meters	
<b>Sound pattern:</b>	ISO 8201	
<b>Silence time:</b>	approx. 10 minutes	
<b>Temperature:</b>	+5° TO +45°C	
<b>Humidity:</b>	90% RH non condensing.	
<b>Dimensions:</b>	Height (recessed)	43 mm
	Diameter	30 mm

# Schedule to Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
<b>afp - 3402</b>	30-Aug-2019	Number 2	Issue date 29-Apr-2021	30-Apr-2022

## Supplementary information

### Schedule of relevant articles

The following schedule is an extract of articles significant and/or related as evidence of conformity.

Reference		Title / description	Date issued (or date validated)	Source
Ident. type	Ident.			
Report	XF3321/R1	Evaluation for Conformity of the Cavius® Model 2008-001 Photoelectric Smoke Alarm with Recess Kit to the requirements of AS 3786-2014 +A1:2015 +A2:2018	21-Jun-2019	CSIRO, Fire Systems Laboratory, AU
User Guide	CAV_2008_10yr_Smoke_User_PRINT_24042019.pdf	CAVIUS User Guide CAVIUS Photoelectric Smoke Alarm Part Code: 2008-001 Model: 2008-003/10019/10020/10021 Recess Kit Part Code: 11010 (CAV_2008_10yr_Smoke_User_PRINT_24042019.pdf)	24-Apr-2019	Cavius Aps, DK